


User Guide & Testing Instructions

Silent Sentry

V Series



Questions? 1.800-765-3237 or visit www.eversafepower.com


Product Information

(Required information when calling for service)

Date of Purchase:

Serial Number:

Facility Information:



Safety & Disclaimer

Intended Use and Equipment & Wiring Connections:

- This UPS system stores energy. Output battery terminals and possibly output breakers or outlets may be live when the system is turned off or after the input power has been disconnected.
- Please be sure to turn off the electricity in the location where the UPS will be installed prior to working on the unit.
- Please be sure that the power supplied to this unit is the proper phase, voltage and amperage specified.
- All hardwired SILENT SENTRY units should be installed by licensed, professional personnel in accordance with local and national codes.
- Although the system is supplied with sealed VRLA batteries they are not *leakproof*. We recommend the unit should not be located near explosive medical gas storage or open flame heaters or electric spark-inducing equipment.

Statement of Liability for Medical Environments

- When used within a surgical environment, do not use in the presence of flammable anesthetic mixtures with air oxygen or nitrous oxide.
- This battery backup power system is not intended to support life or run life supporting equipment but rather to power surgical appliances needed in superficial surgical procedures or medical cold storage appliances. Its use is intended for the supply of emergency power to appliances which may be employed in non-life-threatening medical procedures. It is imperative that it is understood that at no time should a patient remain unattended. At this writing the FDA has no classification for a general-purpose medical emergency power supply. This system is not a medical device.
- All life-support type equipment, life-signs monitors, gas monitors etc. are expected to have their own built-in FDA approved appliance-specific energy sources and be maintained correctly. General room lighting and exit signs are also expected to have multiple independent energy sources.
- If life-supporting equipment is to be powered by any sort of electrical source or device, it is EverSafe expectation that several alternative independent power supply sources and devices be available.
- Appliances such as refrigerators and freezers and the contents being stored within them are the responsibility of the owner/operator to see that they are monitored, maintained and tested. Consequential damages and loss of perishable merchandise are not the liability of EverSafe.
- It is the sole responsibility of the end user or equipment owner to ensure that the battery backup power system has been tested, maintained, and testing records have been kept and filed.

Unit Start Up Procedure:

Upon completing each step of the Installation Guide, keep the unit powered off, then follow these steps to start using the system:

- 1) Power Up: Switch the Unit to “On” the Inverter On light should illuminate.
- 2) Plug an appliance into the unit’s output (outlets) and ensure that the appliance will run off the battery power.
Note: If you are powering a refrigerator or freezer, make sure you test it long enough to see that the appliance’s compressor turns on, you can speed up this process by opening the door of the appliance.
- 3) Now Apply power to the Power System’s Input side by either plugging the power system into a dedicated outlet or switching on the circuit breaker that feeds the unit’s input power.
- 4) Make sure the Mains On LED light illuminates. One of the charging LED lights should also illuminate, either “bulk”, “absorption” or “float”.

Maintenance Procedures

The EverSafe Silent Sentry contains virtually no moving or lubricated components and therefore requires almost no user maintenance except testing and recordkeeping and periodically replacing the batteries (every 4 years).


The user should be aware that by their nature, battery life is negatively affected by some usage patterns. Of course, batteries are intended to be used, but minimizing deep discharges, and frequent charge / discharge cycles will extend overall life. Their life expectancy will be generally in the range of four to five years. Please refer to the section on Battery Testing for more on this subject

The system has a battery voltage alarm which will sound for below normal battery voltages. Battery voltage indicators should be checked if the alarm sounds. Often a low battery alarm will result from a tripped input supply breaker in the main building electric panel. If this is not the cause, please contact EverSafe promptly.

User Guide & Testing Instructions - Silent Sentry - V Series

Operation:

During normal operation while the unit's input is plugged into a utility power outlet, the mains LED light will be lit as well as the state of charge. If the unit is fully charged float charge should be lit. The unit's settings are all preset so the knob that sets the units current limit is bypassed. The LCD display should indicate "AC1" this is normal. If your units display is not displaying this, please contact support.




When the unit is plugged in and switched to "on" it is ready to use. The unit will switch over to battery power "Inverting" whenever power is lost. When power is restored the unit's charger will automatically recharge its batteries and continue to pass power through to the appliances it is supporting.


The following sequences are LED indications of how the system is operating:

Output Indicators:


Inverting: This indicates there is no input power present, and the inverter is drawing from its batteries:




Excess Overload: The equipment load is exceeding the unit's regular output, reduce the equipment load:




Overload: This indicates that the unit is overloaded due to either a short circuit on the output or the equipment load is too large for the system to support:




Batteries are low: This indicates that the system batteries are low. If the unit is supporting a load, it will not be long before the batteries go dead:



Batteries are dead: This indicates that the battery voltage had gone too low, and the inverter has switched off.




Temperature warning: The unit's internal temperature is reaching a critical level.




User Guide & Testing Instructions - Silent Sentry - V Series


Temperature overload: The unit has reached an internal temperature level that is too high, and the unit shut off:



Battery voltage too high: The unit's battery voltage is too high; be sure the correct batteries are being used and they are installed correctly.




Erratic battery voltage: The unit shut down due to excess ripple voltages out of the battery.




Charging Indicators:


Bulk Charge: The unit has AC input voltage and is bulk charging the battery bank while passing the power through to the equipment load:




Bulk/Absorption Charge: The unit has AC input voltage and is bulk charging but not yet reached absorption voltage yet.




Absorption Charge: The unit has AC input voltage and is absorb charging the battery bank while passing the power through to the equipment load:



Float Charge: The unit has AC input voltage and is float charging the battery bank while passing the power through to the equipment load:




Equalize Mode: The unit has AC input voltage and is equalizing battery bank while passing the power through to the equipment load:




Special Indications:

AC Input Max: The unit is supplied with input power, but the output has reached max input setting.



Power Assist: The unit is supplied with input power, but the output has exceeded the max input setting causing the inverter to assist the support of the load from the batteries.



Troubleshooting & Fault Codes:

V – Series Troubleshooting:

Problem	Cause	Solution
Inverter will not turn on.	The battery voltage is too high or too low for the inverter to start or it is not connected. If your unit has a DC switch be sure it is switched to on.	Check the battery voltage is in the correct range. If the DC voltage is good, check the internal ANL fuse.
Low Battery LED is flashing.	The battery voltage is low	Charge the battery by connecting the input power.
Low Battery LED is illuminated.	The unit has switched off because the battery voltage is too low.	Charge the battery by connecting the input power.
Overload LED is flashing.	The unit's load is higher than its nominal output load size.	Reduce the amount of equipment that the power system is supporting.
Overload LED is illuminated.	The unit switched off because the supported load is too high.	Reduce the amount of equipment that the power system is supporting.

User Guide & Testing Instructions - Silent Sentry - V Series

Problem:	Cause:	Solution:
Low battery and overload LED lights are flashing intermittently	Battery voltage is low due to a high load	Reduce the load and recharge the batteries.
Low battery and overload LED lights are flashing simultaneously.	Ripple voltage from the batteries exceeds 1,5Vrms	Check the battery cables and connections ensure that all connections are tight.
The low battery and overload LED lights are lit up	The unit switched off due to a high battery ripple voltage	Check the battery cables and connections ensure that all connections are tight.
Battery Charger will not operate	AC input voltage is not present.	Check to be sure that the unit is plugged in, or the input circuit is not tripped. Restore input power to the unit if input power has been lost.
	The internal battery fuse is blown	Check the Internal ANL Battery fuse replace it if necessary.
	Battery voltage is too low for the inverter to recognize it.	Recharge the batteries with an external charger.
The Charger will not operate but the mains LED and the Bulk LED are lit.	The unit has been in bulk charge too long (over 10 hours)	Check the batteries and all the battery connections. Replace the batteries if they will not charge or will not hold a charge.

Qualified Technical Support & Procedures:

Adjustments can be made to the inverter module. Please consult with technical service prior to making any adjustments, as unit should arrive with adjustments preset.

A large amount of energy is stored in the batteries which can cause injury to unqualified persons attempting to effect repairs. Also, no one untrained regarding electrical energy should attempt any service task or remove any of the front covers as live circuits will be exposed in all cases.

Eye protection should be worn by any person connecting or disconnecting batteries and battery cables.

Hand & Eye Protection is recommended for any person handling batteries.

Various battery connection patterns are used on several model variations. Battery replacements must follow the original factory configuration.

Testing Procedures

Standards of testing the power system must be implemented and carried along with regular testing.

EverSafe sets out the following guidelines and instructions that must be understood and implemented for the use and dependence on our battery backup generators.

Weekly, Monthly and Annual load tests must be performed, recorded and documented. The following criteria must be followed to complete each test:

Weekly Testing:

The recommended weekly test is a quick and simple test which assures the functionality of the transfer switch, auto-invert and charge mode.

This test is performed by disconnecting the power that feeds the battery backup unit or if your system is a plug and play standalone system, unplug its power cord. Upon disconnecting the feed power, your system should switch over to invert mode and draw its power from the batteries. At this point, you should be sure your equipment is still on and running.

Note: If you need to find out your “runtime” contact tech support with your power system’s model and serial number and the make and model of the refrigerator or freezer you are supporting. If you are supporting operating room equipment the standard runtime is 2 hours.

After you have ensured that your system has switched over is inverting, you will need to restore the feed power (or re-plug the system in). This test should not last more than 2 to 3 minutes.

Monthly Testing:

The monthly test is a load test that needs to be conducted no sooner than 20 days and no longer than 40 days from the prior (monthly) load test. This test is to ensure the generator can last 25% of its intended runtime. Your runtime is a predetermined amount of time that your refrigerator will run on the battery backup. This would have been calculated at the time you purchased the unit.

For the week you are performing the monthly test, it is not necessary to also perform the weekly test.

Example: 12 hour run time = Monthly test 3 hours

Another important issue to take note of is that it is possible to over test your power system. EverSafe battery backup system’s use of AGM batteries, which if they are discharged too frequently or discharged too deeply, it can cause damage to the batteries, shorting their life expectancy and weakening them.

You may want to set a timer to remind you to restore the input power to the system and not over discharge the batteries. Reconnect the input power and recharge the battery bank. This may take several hours.

Record Keeping:

Recording these tests is important for the protection of your vaccines and costly inventory. You can use our test logs that are in our service manuals and can download from our website.

Battery Replacement:

Eye protection should be worn by any person connecting or disconnecting batteries and battery cables.


The Batteries are to be replaced every 48 months. To order replacement batteries contact EverSafe 1.800-765-3237

It is better to have someone that is comfortable working with electrical appliances and/or batteries replace them. Often your Bio-Medical, building maintenance or someone of that caliber is best suited to the job. Have them follow the following instructions for battery replacement:

- 1) Disconnect the Input Power by unplugging the unit or switching off the input circuit breaker.
- 2) 1200/2000watt systems: switch it to "Line Charge Only" 4000/4400/8800watt system: Turn the Red DC disconnect knob to the "off" position.
- 3) Remove the front battery box covers to access the batteries – Take a photo of the battery connections or special note of how your batteries cables are configured so you can refer back to it when reinstalling.
- 4) Remove the battery cables:
12 Volt Systems: Remove the entire positive cable set before removing any negative connections.
24- or 48-Volt Systems: Start by removing one of the jumper cables between the batteries.

This will help prevent the cables from accidentally shorting out against the cabinet or each other.

- 5) Remove the batteries from the cabinet and slide the new ones into place
- 6) Re-Install the cables. – Refer to the diagram below:
- 7) Reinstall the Battery Box Covers.
- 8) Follow the Start Up and Testing Procedures within this manual



User Guide & Testing Instructions - Silent Sentry - V Series

The dialer is intended to send a telephone alert when there is a power outage. This system will dial up to 4 numbers when the input power is lost.

Installation Requirements:

- 1) The refrigerator battery backup system operates with a standard analog telephone line. You will need to have this telephone line installed and working prior to installing the power system.
- 2) The System also requires 6 size C standard alkaline batteries.
- 3) This alert is pre-mounted to the face of the battery backup system, so no preparation for mounting this optional remote is necessary.

Programming and Setup:

Plug the system into a phone line using the cord provided (there is an input and extension jack on the top left of the monitor panel) and install the batteries by removing the battery cover in the front of the unit.

You will need to complete the following steps to configure your device:

1) SET THE CLOCK

- a) Press SET
- b) Press CLOCK (Button #8)
- c) Using the number keys, enter the correct time. (It will recite the digits as they are pressed)
- d) If the time is AM, press the AM key. (It will say "am")
If the time is PM, press the PM Key. (It will say "pm")

Example: You want to set the clock to 9:45 am, press the following keys in the order shown: SET + CLOCK + 9 + 4 + 5 + AM

2) SET THE DIAL OUT PHONE NUMBERS:

You can program up to 4 phone numbers which the alarm will call when a power outage occurs. Decide which ones you want to alert and write them down, so they are handy.

- a) Press SET
- b) Press PHONE NUMBER
- c) Select which telephone number to program. Press any unassigned number key (from 1 to 4) to represent the new telephone number entry. (It will respond: "Enter number.")
- d) Enter the complete telephone number using the number keys. (It will recite the digits as they are pressed)
- e) Press ENTER. (The unit will respond: "Okay.")
- f) Repeat above procedure to program up to four separate telephone numbers

4) SET THE INTERCALL TIME

You use this feature only if you are programming in one contact number. It will prevent the system from calling the phone number every minute, which is the default setting.

(If you programmed more than one dial out phone number in step 2, skip this step and move on to step 5)

- a) Press SET.
- b) Press INTERCALL TIME. (Button #3) INTERCALL TIME The Model 400 will respond: "Enter minutes."
- c) Using the number keys, enter the minutes (we recommend 30 and it will recite the digits as you press them).
- d) Press ENTER. (It will respond: "Enter seconds.")
- f) Enter 00 (It will recite the digits as you press them.)
- g) Press ENTER (It will respond: "Okay".)

User Guide & Testing Instructions - Silent Sentry - V Series

5) **SET THE MAX CALLS:**

This will determine the number of times the system will call you after the power goes out and after the power has been restored. We recommend limiting it to 3 calls per user. So, if you only have one call-out number, you will want to set your max calls to 3.
Example: 3 Users X 3 Calls per user = Max Call should be set to 9

- a) Press MAX CALLS. (It will respond: "Enter number.")
- b) Using the number keys, enter the max number of calls you wish (3 times the number of users).
- c) Press ENTER. (it will respond: "Okay".)

Congratulations, you have set up your battery backup remote alert system.

Using the (optional) Remote Alert System:

Once you have the system set up, there is not much to do other than test the system.

Weekly Testing: When you perform your weekly test of the power system by disconnecting the input power, the system will call you with an alert.

Once you reconnect the input power, it should alert you again stating that the system is back to normal.

Important Note: Acknowledging Alerts

When you receive a call from the system, the system may keep calling you until you acknowledge that you have received the alert

At any time during the call, you can enter the acknowledgement code by entering 555.

Once you enter 555, the system will say "Alarm Acknowledged" and stop calling you.

User Guide & Testing Instructions - Silent Sentry - V Series

WARRANTY ACTIVATION FORM

EverSafe warrants that your SILENT SENTRY™ Emergency Power System is assembled using high quality components and workmanship and is free of defects in material and workmanship.

This warranty shall remain in effect for two (2) years from the date of original consumer purchase of the inverter. Warranty on the batteries is pro-rated over 30 months.

THIS WARRANTY DOES NOT COVER:

- 1) Replacement parts or labor furnished by anyone other than EverSafe approved service agent. (All approved agents should be licensed electricians or bio-medical technicians or as specifically approved.)
- 2) Defects or damage caused by labor furnished by someone other than EverSafe or approved service agent.
- 3) Any malfunction or failure of this product while it is in the possession of the owner during the warranty period if the malfunction or failure is not caused by a defect in material and workmanship of EverSafe or if the malfunction or failure is caused by unreasonable use, including the failure to verify the equipment's utility and usefulness prior to emergency conditions.
- 4) Normal battery depletion.

ALSO:

- 1) This warranty is non-transferable to other owners of the product during the warranty period without the express written consent of EverSafe.
- 2) EverSafe reserves the right to repair, replace, or allow credit for any material returned under this warranty. Any damage caused by the customer will be charged or deducted from this allowance.
- 3) All warranty work will be performed at EverSafe factory or using a valid Warranty Authorization Number (WAN) prior to repair. Products shall be delivered to EverSafe factory freight prepaid and fully insured.

The inverter manufacturer's owner's manual is provided. The owner should become conversant with it and with this owner's manual. Before operating your SILENT SENTRY™ be sure to read these safety instructions.

TO INITIATE YOUR WARRANTY PLEASE COMPLETE THIS FORM AND RETURN WITHIN 30 DAYS

It is recommended that you keep a copy of this activation form for your own records.

Model Number: _____ Serial Number: _____

Date of installation: _____ Facility Name: _____

Contact Name: _____ Phone Number: _____

Fax Number: _____ Email Address: _____

Address where System is installed: _____